

East Ayrshire Council

Spa Pool Monitoring Record – Holiday Lets

Expected Parameters (refer to manufacturer’s instructions and guidance HSG 282)

Temperature- Typically 30–40 °C.
 Disinfectant- Chlorine 3–5 mg/l Bromine 4–6 mg/l
 Combined Chlorine - 0<1 mg/l
 pH - between 7-7.6

Location of spa pool:

Saturday Date:

| Check | Check 1 Time: | Check 2 Time: | Check 3 Time: |
|----------------------|---------------|---------------|---------------|
| Clarity and colour | | | |
| Users in pool | | | |
| Temperature | | | |
| Free Cl or Br (mg/L) | | | |
| Combined Cl (mg/L) | | | |
| pH | | | |
| Initials | | | |
| Corrective actions | | | |

Sunday Date:

| Check | Check 1 Time: | Check 2 Time: | Check 3 Time: |
|----------------------|---------------|---------------|---------------|
| Clarity and colour | | | |
| Users in pool | | | |
| Temperature | | | |
| Free Cl or Br (mg/L) | | | |
| Combined Cl (mg/L) | | | |
| pH | | | |

| | | | |
|--------------------|--|--|--|
| Initials | | | |
| Corrective actions | | | |

Monday Date:

| Check | Check 1 Time: | Check 2 Time: | Check 3 Time: |
|----------------------|---------------|---------------|---------------|
| Clarity and colour | | | |
| Users in pool | | | |
| Temperature | | | |
| Free Cl or Br (mg/L) | | | |
| Combined Cl (mg/L) | | | |
| pH | | | |
| Initials | | | |
| Corrective actions | | | |

Tuesday Date:

| Check | Check 1 Time: | Check 2 Time: | Check 3 Time: |
|----------------------|---------------|---------------|---------------|
| Clarity and colour | | | |
| Users in pool | | | |
| Temperature | | | |
| Free Cl or Br (mg/L) | | | |
| Combined Cl (mg/L) | | | |
| pH | | | |
| Initials | | | |
| Corrective actions | | | |

| | |
|--|--|
| | |
|--|--|

Wednesday Date:

| Check | Check 1 Time: | Check 2 Time: | Check 3 Time: |
|----------------------|---------------|---------------|---------------|
| Clarity and colour | | | |
| Users in pool | | | |
| Temperature | | | |
| Free Cl or Br (mg/L) | | | |
| Combined Cl (mg/L) | | | |
| pH | | | |
| Initials | | | |
| Corrective actions | | | |

Thursday Date:

| Check | Check 1 Time: | Check 2 Time: | Check 3 Time: |
|----------------------|---------------|---------------|---------------|
| Clarity and colour | | | |
| Users in pool | | | |
| Temperature | | | |
| Free Cl or Br (mg/L) | | | |
| Combined Cl (mg/L) | | | |
| pH | | | |
| Initials | | | |
| Corrective actions | | | |

Friday

Date:

| Check | Check 1 Time: | Check 2 Time: | Check 3 Time: |
|----------------------|---------------|---------------|---------------|
| Clarity and colour | | | |
| Users in pool | | | |
| Temperature | | | |
| Free Cl or Br (mg/L) | | | |
| Combined Cl (mg/L) | | | |
| pH | | | |
| Initials | | | |
| Corrective actions | | | |

Cleaning and Maintenance

| Daily | Day | Sa | Su | Mo | Tu | We | Th | Fr |
|--|------------------------------------|----|----|----|----|----|----|----|
| | Water line | | | | | | | |
| Overflow channels | | | | | | | | |
| Strainers and grilles | | | | | | | | |
| Surrounds | | | | | | | | |
| Filter check | | | | | | | | |
| Weekly (or after each group of guests, whichever is sooner) | Drain and clean whole system | | | | | | | |
| | Areas behind headrests | | | | | | | |
| | Covers and lids | | | | | | | |

| | | |
|----------------|--|--|
| Monthly | Remove jets | |
| | Inspect jets and accessible pipework for biofilm | |
| | Clean and disinfect as necessary | |
| | Microbiological samples sent | |

For more information, contact East Ayrshire Council’s Environmental Health team by email environmentalhealth@east-ayrshire.gov.uk .

In the event of checks being out with the required parameters- Refer to your manufacturer’s instructions in addition to, The control of legionella and other infectious agents in spa-pool systems (HSG 282)

<https://www.hse.gov.uk/pubns/priced/hsg282.pdf> and Legionnaires’ disease

The control of legionella bacteria in water systems (L8)

<https://www.hse.gov.uk/pubns/priced/l8.pdf>